

Australia and New Zealand Certificate of Suitability- addendum

Certificate
ULL-104214-A1

Issue date
2026-07-31

Expiration date
2030-11-10



www.jasanz.org/register

This is to acknowledge that

FOSHAN MIDEA CARRIER AIR- CONDITIONING EQUIPMENT CO LTD

Lingang Road No.22, Beijiao Town, Shunde, Foshan, Guangdong, 528311
China

has had

Multi split-type air conditioner

[refer following page(s) for models list]

evaluated and meets the requirements of the standard(s)

**AS/NZS 60335.2.40:2023, Amd 1: 2025; AS/NZS
60335.1:2020, Amd 1: 2021**

Certificate of Suitability issued under Queensland Government's
Recognised External Certification Scheme (RECS)
ANZ Certification Scheme requirements.



Jacky Wong (Certification Officer)

Certification Body:
UL International New Zealand Limited,
54 Tarndale Grove, Albany, Auckland 0632, New Zealand.

Issued for use in Australia and New Zealand only.
All dates are in Year-Month-Day format (YYYY-MM-DD).

Australia and New Zealand Certificate of Suitability-addendum

Certificate No: ULL-104214-A1

Original Date of Certification: 2025-11-10

Date of Issue/Revision: 2026-07-31

Trade Name or Trademark: Carrier

Risk Class / NSW Declared Class: LEVEL 2 - Air conditioner incorporating non-flammable refrigerant: (or low flammable refrigerant)

IEC Standard Country Differences: AU and NZ

Certification Marking: The RCM mark must be applied to the product and all the requirements of all relevant parts of AS/NZS 4417 applicable to the article shall be fulfilled.

Additional Certification Conditions: AS/NZS 60335.1:2020 Corrigendum 1 issued Nov 2022 applied.

Model Details:

Model Name	Marked Input Voltage	Marked Input Frequency	Marked Input Current	Marked Input Power	Insulation Class
42QCE020N8S					Class I
38QUM080D8S4-1	220-240 Vac	50 Hz	19.0 A	4150 W	Class I
38QUM190D8S6-2	220-240 Vac	50 Hz	33 A		Class I
38QUM170D8S6-2	220-240 Vac	50 Hz	33 A		Class I
38QUM190D8S6-1	220-240 Vac	50 Hz	30.4 A		Class I
38QUM170D8S6-1	220-240 Vac	50 Hz	30.4 A		Class I
38QUM170D8S5	220-240 Vac	50 Hz	32 A		Class I
38QUM190D8S6	220-240 Vac	50 Hz	32 A		Class I
42QCE026N8					Class I
42QCE035N8S					Class I
42QCE050N8					Class I
38QUM110D8S5	220-240 Vac	50 Hz	30.0 A	6900 W	Class I

Additional Information:

Indoor unit: 42QCE020N8S, 42QCE026N8, 42QCE035N8S, 42QCE050N8.

Outdoor unit: 38QUM080D8S4-1, 38QUM110D8S5, 38QUM190D8S6. 38QUM190D8S6-2, 38QUM170D8S6-2, 38QUM190D8S6-1, 38QUM170D8S6-1 and 38QUM170D8S5, R32 refrigerant

Details of Addendum:

- Models 38QUM190D8S6-2, 38QUM170D8S6-2, 38QUM190D8S6-1, 38QUM170D8S6-1 and 38QUM170D8S5 added.
- Correction in rating for model 38QUM190D8S6 to 32 A.